

Inspection Record for Installation Acceptance of Safeguarding System and/or Sequential System

Record No.: _____

Client: _____	Subcontractor: _____
Project No.: _____	Subcontract P.O. No.: _____
Project Name: _____	

<u>Additional Information:</u>	Purchase Order No.:
Description of items accepted:	Manufacturer:

Reference Document: _____

Items to inspect	Subcontractor	Company		Remarks
	inspected initials/date	Hold Point	inspected* initials/date	
1.0 All loop function trip checks complete/correct				
2.0 Cabinet check sheets complete and correct				
3.0 Earthing system complete and correct				
4.0 System printer operating correctly				
5.0 First failure system operating correctly				
6.0 Functional test - loop by loop				
7.0 Carry out all settings				
8.0 Power supply switches				
9.0 Front lamps				
10.0 Cabling and wiring				
Remarks/note: If PLC used for safeguarding inspection Logics/safeguarding narrative shall be used for testing				

H - Company's presence is mandatory for all activities in section. Attachments, No. of pages: _____
 h - Company's presence is mandatory.

Accepted for Subcontractor	Accepted for Company	Accepted for Client
Name: _____	Name: _____	Name: _____
Signature: _____	Signature: _____	Signature: _____
Date: _____	Date: _____	Date: _____

* Company only initials for holdpoint