Cable Insulation and Continuity Test Report Instrument Cables			Report No.: ——
Client:	Subcontractor:		
Project No.:	Subcontract P.	O. No.:	
Project Name:	Multicore Cable	· No ·	
		Junction Box No.:	
	Junction Box iv	U	
Reference Document:			
Cable No.	Continuity	Insulation	Signed
Notes: During testing all cables and wiring r	nust he completely disconnected fr	om any oquinment	
Screens shall be checked as commo		om any equipment.	
Insulation test:			
Between signal wires			
2. Each core to ground Continuity/point to wire check (with le Check correct installation of cable gl Check cable identification tags Check that cables, wiring, ducting, t Isolation test-shield/armoring to ground	ands rays and fittings are complete and s	secured	
Remarks:			
Accepted for Subcontractor	Accepted for Com	pany Accepted for	Client
Name:	Name:	Name: ——	_
Signature:	Signature:	Signature:	
Data:	Data:	Data:	